

# **Design and Field Test of a Full Scale Performance Augmentation Network (PAN)**

## **2014 GMRC Research Project**

**W. Norman Shade, PE & John J. Bazaar, ACI Services, Inc.**

**Kelly Eberle & Mehdi Arjmand, Beta Machinery Analysis**

**Glen F. Chatfield & Dale K. Wells, OPTIMUM Pumping Technology**

**Scott Schubring, Williams**

## End User Interest and Objectives

- **Support advancement of new technology**
- **Significant commercial benefit from**
  - **More flow from compressors for given driver size & rating**
  - **Higher efficiency reduces fuel cost & specific exhaust emissions**
  - **Reduce no. & size of multiple parallel drivers at a station**
- **Such advancements may become mandatory in future**
  - **Recently announced DOE efficiency initiative**
  - **EPA GHG reduction initiatives**



## **PAN & Bottle Systems Are Fundamentally Different**

|                                 | <b><u>Bottle Systems</u></b>  | <b><u>PAN Systems</u></b>   |
|---------------------------------|---|---|
| <b>Pulsation energy</b>         | <b>95% dissipated</b>   | <b>95% recovered</b>  |
| <b>Throw phasing</b>            | <b>Individually</b>   | <b><u>all</u> throws Interleaved</b>  |
| <b>Pressure &amp; HP losses</b> | <b>can be large</b>   | <b>Insignificant</b>  |
| <b>Components</b>               | <b>expansion bottles<br/>baffles<br/>choke tubes<br/>orifice plates</b> | <b>tuned pipe lengths<br/>tuned pipe diameters<br/>primary Y or W junctions<br/>secondary Y junctions</b> |

## **Brief PAN Technology Development History**

- **1994 engine technology development begins with Univ. of Belfast**
- **2006 modeled 1<sup>st</sup> compressor cylinder**
- **2007 GMC paper on 1<sup>st</sup> PAN compressor model**
- **2008 GMC paper on lab air compressor PAN testing**
- **2009 GMC paper on TGT Ellisburg station PAN field test**
- **2010 El Paso sta. 96 PAN conversion designed; project suspended**
- **2011 GMRC project - PAN conversion at El Paso Batesville station**
- **2011 GMC paper on efficiency increase with PAN tuning**
- **2012 El Paso sale cancelled Batesville host & GMRC project on hold**
- **2013 GMRC project - PAN conversion at Williams sta. 85; withdrawn**
- **2014 GMRC project – Williams Zick station (this paper!)**

## **Project Objectives**

### **Primary**

- **Cover operating range from 450-900 suction & 1000-1200 discharge**
- **Maximize capacity at all conditions at rated power & speed**
- **Total system (line to line) pressure drop <2.0 psig at all conditions**
- **Control pulsations to <1.5% of line pressure level at all conditions**
- **Control mechanical vibrations and stress levels to API 618 M5**
- **10% reduction in BHP/MMSCFD at the high flow condition  
(compared to existing bottle unit)**

### **Secondary**

- **Validate predictive accuracy of OPT VPS software**
- **Demonstrate ability to create optimal PAN that simultaneously achieves all objectives**
- **Achieve performance with unloading limited to HE VVCPs**
- **Fit factory-built PAN entirely onto the compressor package skid**
- **Dependable operation over 1300 to 1400 rpm speed range**

## **Compressor Package Specifications**

- **Caterpillar G3516 gas engine driver**
- **1380 BHP @ 1400 rpm**
- **Ariel JGT/4 4.5” stroke compressor**
- **(4) 6.75” cylinders with HE VVCP**
- **Single stage**
- **Suction pressure 450 to 900 psig**
- **Discharge pressure 1000 to 1200 psig**
- **Separate motor-driven cooler**
- **Single suction scrubber**

## **Specified PAN System Design Points**

| <b><u>Operating Condition</u></b>                  | <b><u>Suction Pressure (psig)</u></b> | <b><u>Discharge Pressure (psig)</u></b> |
|--|---------------------------------------|---|
| <b>Low suct; Low disch. (low flow)</b>             | <b>450</b>                            | <b>1000</b>                             |
| <b>Low suct; high disch. (high ratio)</b>          | <b>450</b>                            | <b>1200</b>                             |
| <b>Center of operating map (design pt.)</b>        | <b>675</b>                            | <b>1100</b>                             |
| <b>High suct; low disch. (low ratio/high flow)</b> | <b>900</b>                            | <b>1000</b>                             |
| <b>High suct; high disch.</b>                      | <b>900</b>                            | <b>1200</b>                             |


# Predicted PAN Performance

## Pressure Drop

Total PAN Suction plus Discharge Pressure Loss

GOAL < 2 psi


@ 1300 bhp, 1400 rpm



# Predicted PAN Performance

## Suction Pulsation

PAN Suction Pulsation as % of Suction Pressure  
Goal < 1.5%  
@ 1300 bhp, 1400 rpm




# Predicted PAN Performance

## Discharge Pulsation

PAN Discharge Pulsation as a % of Discharge Pressure

Goal < 1.5%

@ 1300 bhp, 1400 rpm



## Predicted Pressure Drop Reduction

### PAN Unit vs. Baseline Bottle Unit

1300 BHP @1400 rpm

| <b>Unit #8 (PAN) vs. Unit #1 pressure drop reduction</b> |             |             |             |             |             |
|--|-------------|-------------|-------------|-------------|-------------|
|  | <b>1000</b> | <b>1050</b> | <b>1100</b> | <b>1150</b> | <b>1200</b> |
| <b>450</b>   | 92.8%       | 93.1%       | 92.9%       | 96.0%       | 93.7%       |
| <b>495</b>   | 98.3%       | 90.5%       | 96.1%       | 93.1%       | 96.2%       |
| <b>540</b>   | 91.6%       | 92.9%       | 92.6%       | 88.4%       | 93.1%       |
| <b>585</b>   | 90.9%       | 91.2%       | 88.8%       | 92.4%       | 88.8%       |
| <b>630</b>   | 93.6%       | 91.8%       | 87.6%       | 89.6%       | 91.7%       |
| <b>675</b>   | 89.4%       | 93.7%       | 90.5%       | 89.6%       | 91.7%       |
| <b>720</b>   | 88.8%       | 86.3%       | 91.5%       | 89.6%       | 91.7%       |
| <b>765</b>   | 90.6%       | 91.6%       | 91.1%       | 89.6%       | 91.7%       |
| <b>810</b>   | 92.7%       | 93.3%       | 91.8%       | 90.8%       | 91.7%       |
| <b>855</b>   | 92.8%       | 93.0%       | 89.3%       | 92.0%       | 91.7%       |
| <b>900</b>   | 91.2%       | 92.5%       | 85.2%       | 90.6%       | 88.0%       |

**Table Average – 91.5%**

**Predicted Flow Increase (MMSCFD)**

**PAN Unit vs. Baseline Bottle Unit**


1300 BHP @1400 rpm

| <b>Unit #8 (PAN) vs. Unit #1 flow improvement (MMSCFD)</b> |             |             |             |             |             |
|--|-------------|-------------|-------------|-------------|-------------|
|  | <b>1000</b> | <b>1050</b> | <b>1100</b> | <b>1150</b> | <b>1200</b> |
| <b>450</b>   | 1.7         | 1.3         | 1.1         | 0.8         | 0.6         |
| <b>495</b>   | 2.5         | 2.0         | 1.5         | 1.1         | 0.8         |
| <b>540</b>   | 3.4         | 2.8         | 1.9         | 1.4         | 1.8         |
| <b>585</b>   | 4.9         | 3.7         | 2.9         | 2.2         | 5.6         |
| <b>630</b>   | 6.1         | 5.0         | 3.8         | 7.3         | 10.0        |
| <b>675</b>   | 8.8         | 6.8         | 4.8         | 7.3         | 10.0        |
| <b>720</b>   | 12.3        | 9.4         | 6.8         | 7.3         | 10.0        |
| <b>765</b>   | 14.6        | 13.2        | 9.2         | 7.3         | 10.0        |
| <b>810</b>   | 15.8        | 15.4        | 13.2        | 10.6        | 10.0        |
| <b>855</b>   | 18.1        | 16.8        | 15.6        | 13.9        | 10.0        |
| <b>900</b>   | 19.8        | 18.8        | 17.4        | 16.6        | 13.6        |

**Table Average – 8.0**

# Predicted Flow Increase (MMSCFD) PAN Unit vs. Baseline Bottle Unit

Incremental Unit #8 Flow in MMSCFD  
@ 1300 bhp, 1400 rpm



**Predicted % Improvement in BHP/MMSCFD**

**PAN Unit vs. Baseline Bottle Unit**


1300 BHP @1400 rpm

| <b>Unit #8 (PAN) vs. Unit #1 HP/MMSCFD reduction</b> |             |             |             |             |             |
|--|-------------|-------------|-------------|-------------|-------------|
|  | <b>1000</b> | <b>1050</b> | <b>1100</b> | <b>1150</b> | <b>1200</b> |
| <b>450</b>   | 5.7%        | 4.5%        | 3.7%        | 3.3%        | 2.5%        |
| <b>495</b>   | 6.7%        | 5.6%        | 4.8%        | 3.8%        | 3.0%        |
| <b>540</b>   | 8.0%        | 6.6%        | 5.5%        | 4.4%        | 4.9%        |
| <b>585</b>   | 9.9%        | 8.1%        | 6.9%        | 5.5%        | 14.4%       |
| <b>630</b>   | 10.9%       | 9.6%        | 7.9%        | 16.4%       | 23.7%       |
| <b>675</b>   | 13.3%       | 11.4%       | 9.3%        | 16.4%       | 23.7%       |
| <b>720</b>   | 15.8%       | 13.8%       | 11.0%       | 16.4%       | 23.7%       |
| <b>765</b>   | 18.5%       | 16.1%       | 12.9%       | 16.4%       | 23.7%       |
| <b>810</b>   | 21.5%       | 18.6%       | 16.0%       | 16.2%       | 23.7%       |
| <b>855</b>   | 25.5%       | 21.6%       | 18.6%       | 15.9%       | 23.7%       |
| <b>900</b>   | 30.5%       | 25.3%       | 21.5%       | 18.8%       | 15.4%       |


**Table Average – 13.5%**

# Predicted % Improvement in BHP/MMSCFD PAN Unit vs. Baseline Bottle Unit

Improved Unit #8 Efficiency - Reduced bhp/MMSCFD  
@ 1300 bhp, 1400 rpm




## Existing Bottle Unit




- G3516 gas engine
- JGT/4 compressor
- 6.0" cylinders
- Engine driven cooler
- 1300 BHP @ 1400 rpm

## PAN Mechanical Design 3-D CAD Model




## PAN Mechanical Design 3-D CAD Model




## **PAN Mechanical Design Completed Package**




## **PAN Mechanical Design Completed Package**



## PAN Mechanical Design TST-Collectors



8,205-psi Maximum Principal Stress at Internal Rib Location2




- (4) 8x6x6 Y-collectors
- (2) 12x8x8 Y-collectors
- ASTM A395 Cast DI
- 1500 psig MAWP
- Serialized Items


# PAN Mechanical Analysis FEA Model




**Rear**



**Front**




**Frame**




# Dynamic Loads

- Compressor reciprocating and rotating inertia
- Cylinder gas force (stretch force)
- Crosshead guide force
- Pressure pulsations




## PAN Mechanical Analysis Pulsation Model




# PAN Mechanical Analysis

## Maximum Shaking Forces - Suction




# PAN Mechanical Analysis

## Maximum Shaking Forces - Discharge




# PAN Modal Analysis & Mechanical Forces Response Analysis

## Vibration Result at 81 Hz




# PAN Modal Analysis & Mechanical Forces Response Analysis

## Vibration Result at 81 Hz – Cyl. 1 & 3 Side View



# PAN Modal Analysis & Mechanical Forces Response Analysis

## Dynamic Stress at 81 Hz




ANSYS 15.0  
APR 14 2014  
10:16:04  
PLOT NO. 1  
ELEMENT SOLUTION  
STEP=9999  
SEQV (NOAVG)  
PowerGraphics  
EFACET=1  
DMX =.008197  
SMN =.157611  
SMX =3459.37  
.157611  
384.514  
768.871  
1153.23  
1537.58  
1921.94  
2306.3  
2690.66  
3075.01  
3459.37

## Preliminary Results

- Vibration = 4.1 ips peak at 81 Hz
  - Guideline is 1 ips peak
- Dynamic stress = 3,460 psi peak at 81 Hz
  - Guideline is 1,500 psi peak
- Assumptions
  - 81 Hz resonance occurs (81 Hz at 4x = 1215 rpm). Normal operating speed is 1300-1400 rpm.
  - Damping ratio is 1%. Typical damping ratio for this mode is 2% to 4%.
- Vibration and dynamic stress will be lower at normal operating speed and higher damping


# PAN Modal Analysis & Mechanical Forces Response Analysis

## Vibration Summary for Condition 4 Assuming 2% Damping




# PAN Modal Analysis & Mechanical Forces Response Analysis

## Dynamic Stress Summary for Condition 4 Assuming 2% Damping



## PAN Modal Analysis & Mechanical Forces Response Analysis Scrubber Detuning



**Recently scrubber inlet piping design was finalized. Potential scrubber resonance.**

**Proposed Solution: Skirt Cut-out**

12" to 18"  
diameter  
cut-out in  
skirt




## **PAN Modal Analysis & Mechanical Forces Response Analysis Mechanical Recommendations**

- **Design & assembly care to avoid pipe strain**
- **Small bore piping natural frequency testing**
- **Shop bump testing to verify model MNF predictions**
- **Shop bump testing to verify damping ratio assumptions**
- **Field bump testing to verify MNF placement & response**
- **Running test to verify acceptable vibration limits at first start-up**
- **Inspect pipe clamps, flange studs & other critical fasteners at regular intervals to ensure there is no vibratory loosening.**


## **Field Performance Testing**

- **Steady state tests at 5 specified points – 1300 BHP @ 1400 rpm**
- **Data also recorded during speed and pressure transient sweeps**
- **Multiple pressure points on both PAN & existing bottle unit**
- **Both units will be tested simultaneously at each operating point**
- **Enthalpy rise measured between system suction & discharge**
- **AGA flow meters on each unit suction**
- **Laboratory grade instrumentation and (3) data acquisition systems**
- **All cylinder ends indicated with (3) Windrock analyzers**
- **Valve losses indicated**
- **Crosshead ODC measured for accurate phasing**
- **Engine & panel data recorded for reference only**
- **Pulsations measured throughout both systems (full port valves)**
- **All recording systems time synched**
- **Gas sample at each suction each day**
- **Downstream gas chromatograph log obtained for each day**

## Field Performance Testing PAN System Test Points




LEFT SIDE




RIGHT SIDE

45 PRESSURE TAPS TOTAL FOR UNIT 8

# Field Performance Testing Bottle System Test Points



LEFT SIDE



RIGHT SIDE

46 PRESSURE TAPS TOTAL FOR UNIT 1

## **Field Performance Testing**

- **Test team of 13-14 people with detailed protocol established.**
- **Calculation methods pre-established.**
- **VMG and NIST gas data.**
- **Data adjusted for differences in cylinders (based on predictions).**
- **Comparison of measured and predicted results for both units.**
- **Unfortunately, construction delays prevented test data for paper.**
- **Mechanical testing this week.**
- **Performance testing late October awaiting higher gas flows to reach high end of suction pressure required for test points.**

## **Conclusions**

- **Simulations confirm optimized PAN can cover large range of operating conditions (to be verified by field test).**
- **Higher PAN efficiency mandated choice of larger cylinders to load unit and maximize flow (conflicting end user requirement that complicates the pure research comparison with bottle unit).**
- **Predicted system pressure drop less than 1.0 psig over most of operating range.**
- **Predicted pulsation less than 0.3% of line pressure at all conditions.**
- **-30.5% BHP/MMSCFD predicted improvement at high flow point.**
- **Control of pulsation induced forces within the PAN is challenging.**
- **PAN structural design to avoid MNFs is challenging, but doable.**
- **Fixed speed applications much easier to design.**
- **More to follow in report and paper after field tests are complete.**

**Testing currently planned for wk. of Oct. 27**

Thanks for your attention.

Questions???

