



Predicting the Power Loss of Reciprocating Compressor Manifolds

Project Team:

NOVA Research:

Kamal K. Botros
John Geerligs

Beta Machinery:

Kelly Eberle
Brian Howes
Gordon Sun
Russ Barss
Bryan Long

TransCanada:

Thomas Robinson

Peerless Mfg:


Dave Breindel

PSC:

Martin Hinchliff - chair
Rainer Kurz
Christine Scrivner
Steve O'toole
Clint Lingel

Project Motivation

How much power
does my
compressor need?



Compressor Performance Calculation

Application Data			
Est. Flow	Load/Flow	Est. Flow:: 5.820 MMscfd	
Est. Total Load	Run Speed	Load/Flow: 147.1 HP/MMscfd	
Auxiliary Load	Lubrication	Est. Total Load: 855.9 HP	
Type	ISSUES	Run Speed: 738	
Project Note	Case Note		
Order Status			
Stage/Service Data:			
Flow Rate:	MMscfd	5.82	5.82
Load:	HP	449.3	377.1
Specific Gravity:	-	0.5660	0.5660
K Value (Cp/Cv):	-	1.2788	1.2671
Z:	-	0.9834	0.9867

Why Estimated Total Load?

- Compression (ideal) power ✓
- Mechanical Efficiency ✓
- Manifold (bottle) power loss ?
- Orifice power loss ?
- Other system loss ?

Est. Clr:	Ug. r	10.22	18.78	-	-
Base Clr:	%	10.22	18.78	-	-
Added Clr:	%	0.00	0.00	-	-
Total Clr:	%	10.22	18.78	-	-

How do you calculate the unknown power losses?

BOLD - Out of Limit FILE: RybinskES602 Final.hsr
GE HSR Compressors, its owners, affiliates, authorized distributors or agents assume no liability for any consequences, damages or loss of production as a result of use or misuse of the information or calculations contained in this program.

Compressor Performance Calculation

Unknown Power Losses are estimated by the pressure drop

Application Data:	Compressor Frame: ES602	Driver Data: HP
Order Status: Order: IPS 790743		
Stage/Service Data:	Stage-1	Stage-2
Flow Rate:	MMScfd 5.82	5.82
Load:	HP 449.3	377.1
Specific Gravity:	- 0.5660	0.5660

Suction Press.:	psiA	57.42	168.36
Ps@Flange:	psiA	48.72	148.49
Pd@Flange:	psiA	168.36	391.59
Discharge Press.:	psiA	168.36	383.76

Model:	07 Series	06 Series			
Operating Mode:	D/A Cyl	D/A Cyl			
Head End	Stage	Stg-1	Stg-2	-	-
Bore:	in	21	13	-	-
MAWP:	psiA	263.9106	813.9106	-	-
RDP:	psiA	238.9106	740.9106	-	-
Tail Rod Dia:	in	0	0	-	-
Est. Td:	deg F	239.5	262.3	-	-
VVCP Open:	in : Turns	No VVCP	No VVCP	-	-
Base Clr:	%	11.05	20.06	-	-
Added Clr:	%	0.00	0.00	-	-
Total Clr:	%	11.05	20.06	-	-
Vol. Eff. Suct.:	%	75.21	71.80	-	-
Vol. Eff. Disch.:	%	28.53	33.45	-	-

How much, assume 1%, 2%?
Is it accurate?

Flow:	MMScfd	2.92	2.89	-	-
Valve Spacers:	HE#/CE#	0 / 0	0 / 0	-	-
Rod Loads					
Gas-Compress.:	%	74.3	59.5	-	-
Gas-Tension:	%	72.3	55.2	-	-
Net-Compress.:	%	84.0	67.4	-	-
Net-Tension:	%	85.2	64.5	-	-
Pin Reversal:	Deg/Mag%	173/96	175/91	-	-
Throw Loading	HP	449.3	377.1	-	-

BOLD = Out of Limit FILE: RybinskES602 Final.hsr
 GE HSR Compressors, its owners, affiliates, authorized distributors or agents assume no liability for any consequences, damages or loss of production as a result of use or misuse of the information or calculations contained in this program.


Pressure Drop Calculation... easy, right?

$$h_{loss} = K \frac{V^2}{2g}$$

A	B	C	D	E	F	G	H	I
1 Pipe Flow/Friction Factor Calculations II:								
2 Calculation of pipe diameter, D, for given flow rate, Q, pipe length, L,								
3 pipe roughness, ϵ , head loss, h_L , and fluid properties, ρ & μ .								
4 (NOTE: This is an iterative calculation. An assumed value of D will be used to start.)								
5								
6 1. Determine Friction Factor, f, assuming completely turbulent flow								
7 $[f = 1.14 + 2 \log_{10}(D/\epsilon)]^2$								
8								
9 Inputs Calculations								
10	Allowable Head Loss, h_L	45	ft	Assumed Pipe Diam, D	8	in		
11	Pipe Roughness, ϵ	0.0005	ft	Pipe Diameter, D	0.5667	ft		
12	Pipe Length, L	10	ft	Friction Factor, f	0.01631			
13	Pipe Flow Rate, Q	0.600	cfs					
14	Fluid Density, ρ	1.94	slugs/ft ³					
15	Fluid Viscosity, μ	0.000027	lb-sec/ft ²					
16								
17								
18								
19								
20								
21								
22	2. Check on whether the given flow is "completely turbu							
23	[Calculate f with the transition region equation and see if d							
24	$[f = (-2 \log_{10}[(\epsilon/D)(3.7 + 2.51/(Re \cdot \epsilon))])^{-2}]$							
25								
26	Transition Region Friction Factor, f			f =	0.0190			
27								
28	Repeat calc of f using new value of f			f =	0.0190			
29								
30	Repeat again if necessary			f =	0.0190			
31								
32	3. Calculate pipe diameter, D using the final value for f calculated in step 2							
33	$[D = f(L/h_L)(V^2/2g)]$							
34								
35	Pipe Diameter, D	0.2	ft	=	2	in		
36								



OK, but...does this work for my recip compressor?

Fitting Type	K	Fitting Type	K
Pipe Entry Losses			
Square Inlet	0.50	Gradual Enlargements	
Re-entrant Inlet	0.80	Ratio d/D = 10" typical	0.02
Slightly Rounded Inlet	0.25		0.13
Bellmouth Inlet	0.05		0.29
			0.42
Pipe Intermediate Losses			
Elbows R/D < 0.5		Gradual Contractions	
45°	0.35	Ratio d/D = 10" typical	0.03
90°	1.10		0.08
			0.12
			0.14
Valves			
Long Radius Bends (R/D = 2)		Gate Valve (fully open)	0.25
11 1/2"	0.05	Reflex Valve	2.50
22 1/2"	0.10		
45°	0.20	Globe Valve	10.00
90°	0.50		
Tees			
(a) Flow in line	0.35	Butterfly Valve (fully open)	0.20
(b) Line to branch flow	1.00		
		Angle Valve	5.00
Sudden Enlargements			
Ratio d/D		Foot Valve with strainer	15.00
0.5	0.04		
0.8	0.13	Air Valves	2.00
0.7	0.26		
0.6	0.41		
0.5	0.56		
0.4	0.71		
0.3	0.83		
0.2	0.92		
0.1	1.00		
Sudden Contractions			
Ratio d/D			
0.9	0.19		



Challenges to Industry

- Manifolds (pulsation bottles) have complicated geometry. K-factors are not published.
- Recip compressors create high flow fluctuations.
- How to relate pressure drop to power loss?




How important is power loss?

Inaccurate power calculation effects performance and reliability (3% to 12% error in results)

Consequences:

- Driver size inadequate
- Unable to meet contract flow
- Reliability (rod load, reversal, and discharge temperature)
- Inefficient operation



Overall Project Objectives

1. Develop a methodology to predict the mean and pulsating power losses across Reciprocating Compressor Manifolds (bottles).
2. Validate the methodology via experimental means, either from:
 - Measurements of actual recip. compressor in the field, or
 - Scale-down test rig involving a custom-design bottle and a Pulse-generator.
3. Ultimate Goal is to:
 - Recommend a standard methodology to quantify the pulsating flow power loss.
 - Come up with adjustment factor(s) to be applied to the mean pressure drop coefficient (K) in the presence of pulsating flow.


Overall Project Objectives

1. Develop a methodology to predict the mean and pulsating power losses across Reciprocating Compressor Manifolds (bottles). Completed 2013
2. Validate the methodology via experimental means, either from:
 - Measurements of actual recip. compressor in the field, or
 - **Scale-down test rig involving a custom-design bottle and a Pulse-generator.** Focus of this presentation
3. Ultimate Goal is to:
 - Recommend a standard methodology to quantify the pulsating power loss.
 - Come up with adjustment factor(s) to be applied to the mean pressure drop coefficient (K) in the presence of pulsating flow.

Outline

1. Test Program
2. Measurements and Results
3. Key Findings
4. Next Steps



Test Setup at TCPL's GDTF in Didsbury, Alberta



Pulse Generator


Pulsations will be created by a hydraulically driven rotating paddle

- Not a recip compressor
- Operate at 300 to 1200 rpm.
- Double acting
- Pulse amplitude 1% to 2% line pressure




Test Setup Details


Configuration A: Bottle Upstream, Orifice Downstream





Configuration B: Orifice Upstream, Bottle Downstream



Custom Bottle Design (donated by Peerless Mfg.)



ITEM NO.	DESCRIPTION	QTY.
1	Shell, 16" OD, 15" ID, 12" Long	2
2	Head, 16" OD, 15" ID, 2" Tangent Length	2
3	Flange 16" 600 LBS	2
4	End Treatments, Straight Cut	2
5	Coupling	2
6	Choke Tube 2" Sch XS	1
7	Flat Plate, 0.75" Thick	1
8	RePad, 8.5" OD, 4.5" ID, 0.5" Thick	4
9	Saddle Support Weld Pad, 10" x 5" x 0.5"	2
10	1/2" Threadolet	6
11	Flange, 4" NPS 600 LBS, Nozzle 4" Sch STD	4
12	Gusset	8



It would be preferred that the nozzle in Item 11 be constructed with 4" S40 pipe. Although pressure vessel code must still be met.

 BETA MACHINERY ANALYSIS www.BetaMachinery.com	CLIENT		
	PROJECT		
	LOCATION		
	TITLE: GMRC Pressure Drop Test Bottle		
Calgary, AB (Tel) 403.245.5666 CANADA (Fax) 403.245.3257 Houston, TX (Tel) 281.920.4441 USA (Fax) 281.920.4442	DRAWN BY: MG	DATE: 2014-Feb-5	SCALE: NTS
	REF: 208194	FIGURE:	REV: 01

End Treatments

2-11-1/2 NPSM Straight Pipe Tapped Thread

2" Sch XS

6.5

1

2" x 3" Diffuser

2-11-1/2 NPSM Straight Pipe Tapped Thread

2" Sch XS

6.5

1

1

4.38

50°

Taper

2-11-1/2 NPSM Straight Pipe Tapped Thread


2" Sch XS

6.5

1

Normal (Square)

	CLIENT
	PROJECT



Square End Treatment

2014/07/10



Diffuser End Treatment

2014/07/10

Photos of Configuration A Setup



Flow Direction


Sonic Nozzles Bank

Pulse Generator

Kulite P Transducers

Pair of Dynamic P Transducers
(1.5 m apart)


Static P & T Transducers
(Upstream)



Kulite P Transducers




**Pair of Dynamic P Transducers
(1.5 m apart)**





**Rosemount
Differential P
Transducer**

**Rosemount
Differential P
Transducer**




**Pair of Dynamic P Transducers
(1.5 m apart)**

Pair of Dynamic P Transducers
(1.5 m apart)

Kulite P Transducers

Static P & T Transducers
(Downstream)






Photos of Configuration B Setup











PRIMARY

1478







Example of Pulsating Pressure Measurements (Across the Bottle)



Example of 1st Harmonic \vec{P}_k and \vec{u}_k Mapping (Configuration A)



Example of 1st Harmonic \vec{P}_k and \vec{u}_k Mapping (Configuration B)




Test Results (Configuration A)

Configuration A Test Scope

Configuration A Test Scope				
Test	Number of Sonic Nozzles	End Treatments	Orifice β	Hole(s)
1	3 and 6	Square/Square	1	-
1a	3 and 6	Square/Square	0.5	Single
1b	3 and 6	Square/Square	0.5	Multiple
1c	3 and 6	Square/Square	0.7	Single
1d	3 and 6	Square/Square	0.7	Multiple
2	3 and 6	Square/Diffuser	0.5	Single
3	3 and 6	Taper/Diffuser	0.5	Single
4	3 and 6	Taper/Square	0.5	Single
4a	High flow	Taper/Square	0.7	Single

For each of the sub-configuration and flow rate, a total of 10 tests were conducted at the following frequencies: 0, 11, 13, 15, 17, 22, 27, 31, 35, and 41 Hz. (Total for Configuration A = 180 Tests).

Normalized Pulsating Power Loss (Bottle)




Normalized Velocity Oscillation u_{rms}/U

- TGP Station 54: 8350 HP compressor, 6 throw
 - $u_{\text{rms}}/U=0.7-1.3$
- Gathering compressor: 1775 HP, 4 throw
 - $u_{\text{rms}}/U=0.75$
- Vapour Recovery Compressor: 1200 HP, 6 throw
 - $u_{\text{rms}}/U=0.4$
- Test Setup: Hydraulic driven rotating paddle, 2 HP
 - $u_{\text{rms}}/U=0.3$ max

Current test setup representative of lower power/throw applications.


Pulse Generator modifications could generate $u_{\text{rms}}/U=0.6$

Normalized Pulsating Power Loss (Orifice)




Theoretical K Factor for the Bottle with Square End Treatments

Bottle Theoretical K Coefficient		
NPS 4, ID (d2)	4.026	in
Choke Tube ID (d1)	1.939	in
Vessel ID (D)	14.29	in
Choke tube (L)	26	in
Element	Local K-Factor	K-Factor (Ref NPS4)
Entrance to Bottle, K1	0.85	0.85
Entrance to Choke Tube (square), K2	0.49	9.11
Choke Tube (f=0.014), K3	0.19	3.49
Choke Tube Exit (square), K4	1.00	18.59
Entrance from Bottle to NPS4, K5	0.42	0.42
Sum (Overall K)		32.45
Measured K Factor		25




K is 21% lower than expected.
Why?

Thoughts about why the Measured K Factor for the Bottle is Lower than Theoretical Value




Flow 


Quasi-Steady Hypothesis of Mean Flow Pressure Drop in the Presence of Pulsating Flow




Quasi-Steady Hypothesis of Mean Flow Pressure Drop in the Presence of Pulsating Flow





Quasi-Steady Hypothesis of Mean Flow Pressure Drop in the Presence of Pulsating Flow




Quasi-Steady Hypothesis of Mean Flow Pressure Drop in the Presence of Pulsating Flow




Quasi-Steady Hypothesis of Mean Flow Pressure Drop in the Presence of Pulsating Flow



Current Measurements of Mean Flow Pressure Loss Coefficient (Representative of Suction Bottle)



Normalized Mean Flow Pressure Loss Coefficient (Orifice) – Referenced to NPS4




Test Results (Configuration B)

Configuration B Test Scope


Configuration B Test Scope				
Test	Number of Sonic Nozzles	End Treatments	Orifice β	Hole(s)
1	3 and 6	Square/Square	1	-
1a	3 and 6	Square/Square	0.5	Single
1b	3 and 6	Square/Square	0.5	Multiple
1c	3 and 6	Square/Square	0.7	Single
1d	3 and 6	Square/Square	0.7	Multiple
2	3 and 6	Square/Diffuser	0.5	Single
3	3 and 6	Taper/Diffuser	0.5	Single
4	3 and 6	Taper/Square	0.5	Single

For each of the sub-configuration and flow rate, a total of 10 tests were conducted at the following frequencies: 0, 11, 13, 15, 17, 22, 27, 31, 35, and 41 Hz. (Total for Configuration B = 160 Tests)

Normalized Pulsating Power Loss (Bottle)



Current Measurements of Mean Flow Pressure Loss Coefficient (Representative of **Discharge** Bottle)



Summary of Site Testing


1. Methodology: Successful in validating the Flow Energy (acoustic power) methodology developed in Phase I.
2. Bottle: Differences measured between the bottle loss factor in steady flow and fluctuating flow as compared to published data. A 21% difference for steady flow, 5% for fluctuating flow in the test rig.
3. Orifice: Loss factor for single hole vs multi hole agreed well with published data. Some divergence at maximum test frequency of 41 Hz. Additional testing to investigate higher frequencies.
4. Pulse Generator: could create sufficient pressure fluctuations (2% of line) but flow fluctuations were lower than high power compressor cylinder ($u_{rms}/U < 0.3$).

2014 Project Plan

Task	Status
<p>Field Test</p> <ul style="list-style-type: none">- Design test rig- Fabricate and Install- Execute Test Plan- Data Analysis	<p>Testing completed July 25 Data review and analysis 95% completed.</p>
<p>Report</p>	<p>Complete by end of 2014</p>
<p>Optional Scope: Testing on reciprocating compressor facility</p>	<p>Need a site: TGP Stn 54, lots of information from Phase 1. Other site possible.</p> <p>Design test:</p> <ul style="list-style-type: none">- Fluctuation flow measurement- Compressor performance (P-V curves) and power measurements (torque, motor power)

Suggestions for Future Work

- Addition testing proposed at the TCPL site. Redesign of pulse generator or test rig required to create high flow fluctuations. CFD analysis of components.



- 4 possible journal publications resulting from the work completed.

Thank You and Acknowledgements

- GMRC for Funding the Research Program
- PSC Oversight committee
- Peerless Mfg. (Dave Breindel) for fabricating and donating the Custom Bottle Design used in the present testing program.
- TCPL (Thomas Robinson) for the in-kind contribution of the use of the GDTF in Didsbury, Canada.
- The following individuals for assisting in conducting the tests and data analysis:
 - _ Matthew Kindree, Alex Mantey (NRTC)
 - _ Bill Eckert, Mark DuBois, Mehdi Arjmand (Beta)



Predicting the Power Loss of Reciprocating Compressor Manifolds

Project Team:

NOVA Research:

Kamal K. Botros
John Geerligs

Beta Machinery:

Kelly Eberle
Brian Howes
Gordon Sun
Russ Barss
Bryan Long

TransCanada:

Thomas Robinson

Peerless Mfg:

Dave Breindel

PSC:

Martin Hinchliff - chair
Rainer Kurz
Christine Scrivner
Steve O'toole
Clint Lingel